



Guidance for use of Natural-Cut Trees

MCAS Miramar Fire Department adheres to and enforces the National Fire Protection Association Code also known as the National Fire Code. Placement of Christmas or other natural cut tree shall adhere to the guidance listed below.

Combustible Vegetation [NFPA 1 (2012) 10.14]

Combustible vegetation, including natural cut Christmas trees, shall be in accordance with Section 10.14. [NFPA 1 (2012) 10.14.1]

Christmas tree placement within buildings shall comply with Table 10.14.1.1. [NFPA 1 (2012)10.14.1.1] {*See table below*}

In any occupancy, limited quantities of combustible vegetation shall be permitted where the AHJ determines that adequate safeguards are provided based on the quantity and nature of the combustible vegetation. [NFPA 1 (2012) 10.14.2]

Vegetation and Christmas trees shall not obstruct corridors, exit ways, or other means of egress. [NFPA 1 (2012) 10.14.4]

Only listed electrical lights and wiring shall be used on natural or artificial combustible vegetation, natural or artificial Christmas trees, and other similar decorations. [NFPA 1 (2012)10.14.5]

Open flames such as from candles, lanterns, kerosene heaters, and gas-fired heaters shall not be located on or near combustible vegetation, Christmas trees, or other similar combustible materials. [NFPA 1 (2012) 10.14.7]

Combustible vegetation and natural cut Christmas trees shall not be located near heating vents or other fixed or portable heating devices that could cause it to dry out prematurely or to be ignited. [NFPA 1 (2012) 10.14.8]

Provisions for Natural Cut Trees [NFPA 1 (2012) 10.14.9]

Where a natural cut tree is permitted {*see Table 10.14.1.1 on page 2 for allowable occupancies*}, the bottom end of the trunk shall be cut off with a straight fresh cut at least 1/2 in (13 mm) above the end prior to placing the tree in a stand to allow the tree to absorb water. [NFPA 1 (2012) 10.14.9.1]

The tree shall be placed in a suitable stand with water. **[NFPA 1 (2012) 10.14.9.2]**

The water level shall be maintained above the fresh cut and checked at least once daily. **[NFPA 1(2012) 10.14.9.3]**

The tree shall be removed from the building immediately upon evidence of dryness. **[NFPA 1(2012) 10.14.9.4*]**

A method to check for dryness is to grasp a tree branch with a reasonably firm pressure and pull your hand to you, allowing the branch to slip through your grasp. If the needles fall off readily, the tree does not have adequate moisture content and should be removed. **[NFPA 1 (2012) A.10.14.9.4]**

(See page 2, for table 10.14.1.1)

Table 10.14.1.1 Provisions for Christmas Trees by Occupancy

Occupancy	No Trees Permitted	Cut Tree Permitted With Automatic Sprinkler Systems	Cut Tree Permitted Without Automatic Sprinkler Systems	Balled Tree Permitted
Ambulatory health care				X
Apartment buildings		Within unit	Within Unit	X
Assembly	X			
Board and care	X			
Business		X		X
Daycare		X		X
Detention and correctional	X			
Dormitories	X			
Educational	X			
Health Care				X
Hotels	X			
Industrial		X	X	X
Lodging and rooming				X
Mercantile		X		X
One and two family		X	X	X
Storage		X	X	X